



Ag Buildings Fire Extinguishers

Most Protection

1. A 10-pound ABC type extinguisher is accessible on each floor of a building or within 50 feet of a structure; is mounted; fully charged.
- 2.
3. Only one 10-pound ABC type extinguisher is available or charged; extinguisher is not easily accessible, not mounted; only Class A or Class BC extinguishers are present.
- 4.
5. Fire extinguishers are not charged, are missing, or have never been there.

Least Protection

(over)

Reminders

Fire types:

- Class A---combustible materials (wood, cloth, paper, rubber, and many plastics)
- Class B ---flammable or combustible liquids, flammable gases, greases, and similar materials.
- Class C ---live electrical equipment or circuits

Personal Protective Equipment

Laws, Regulations, Standards, and Guidelines:

Laws, regulations, standards, and guidelines are constantly being updated and revised. Be sure to check the latest version of any document listed below. Be aware that new laws, regulations, standards, and guidelines on this topic may be generated at any time.

The Standard for Portable Fire Extinguishers, NFPA 10.